



ADICHUNCHANAGIRI INSTITUTE OF TECHNOLOGY
DEPARTMENT OF ELECTRICAL & ELECTRONICS ENGINEERING
JYOTHINAGAR, CHIKKAMAGALURU - 577 102

(Affiliated to V.T.U, Belagavi Recognized by A.I.C.T.E, New Delhi)
(Accredited by N.B.A, New Delhi, ISO 9001: 2008 Certified)

Email: gr_veerendra@rediffmail.com, gr_veerendra@gmail.com Ph: -919448945198 , 08262239779 office:
08262-220623,.
Tel Fax: 08262-220063

Energy Audit Action Report

As per the recommendations of Nature Science Foundation that visited the campus for Energy Audit on 22/6/2022, the following suggestions have been submitted to the College:-

- 1) Every electrical equipment that will be replaced in future should be rated 4-5 stars.
- 2) Implementation of Daylight Sensors.
- 3) Taps and pipes that have optimal water usage settings are to be implemented.
- 4) Turn Off Lights/Tap When Not In Use sign boards are to be put in every room.
- 5) The faculty and staff are advised to use Computers and Electronic equipment in Power Saving Mode.
- 6) 1-2 Campus E-Vehicles have to be bought and used in the college.
- 7) All old and non efficient fans have to be replaced by new energy efficient ones.
- 8) The laboratory staff should regularly monitor all the equipments in the lab.
- 9) Each individual building should have a separate energy meter.

Above suggestions have been submitted to the college management. The College Management has looked into all these mentioned points and has agreed to implement it.

Sign of Energy Audit Co-ordinator

Sign & Seal of HOD and Head
Dr. G. R. Veerendra, M.E., Ph.D.
Dept. of Electrical & Electronics Engg
A.I.T., Chikkamagaluru-577102
Karnataka - INDIA

Sign & Seal of Principal
D. C. T. JAYADEVA

Principal B.E., M.Tech., Ph.D
Adichunchanagiri Institute of Technology
CHIKKAMAGALURU-577102

